



Established in  
1927

## INSTITUTE OF PRECISION MECHANICS

Certification Division

01-796 Warszawa, ul. Duchnicka 3

phone (22) 663-43-14,  
(22) 560-25-40

fax (22) 560-29-22

e-mail: [woitan@imp.edu.pl](mailto:woitan@imp.edu.pl)  
<http://www.imp.edu.pl/cert>



AC 041

# CERTIFICATE OF CONFORMITY

No. Nr P41/201/2016 (4796)

ENGLISH EDITION

Name and address of the certificate owner:	Machine Technology Poland Sp. z o. o. ul. Olsztyńska 10, 14-500 Braniewo
Name and address of the manufacturer:	Machine Technology Poland Sp. z o. o. ul. Olsztyńska 10, 14-500 Braniewo
Product name:	<b>Fire Shutter</b>
Commercial name:	<b>Rolled gate</b>
Type (variants):	<b>FF 76</b>
Main features:	<b>Product class: E120 / EI120 (in combination with sprinkler)</b>
PKWiU symbol:	25.11.10.0
The product is in accordance with:	PN-EN 1634-1:2014
According to the report issued by:	Search Laboratory for Fire Testing GryfitLab (Cert. of Accr. AB818)
Date of expiration and certificate validity conditions:	<b>November 30, 2022</b> <b>The certificate is valid only with the identification label made specifically for this product</b>
Rights for using this certificate from Nov. 30, 2019 until Nov. 30, 2022 refer only to products having identical parameters as sample(s) shown for inspection and meeting requirements stated in application No. LBO-836/16.	
Certification of conformity acc. to PKN-ISO/IEC Guide 67, System 3	

**MANAGER**  
Certification Division

*Wojciech DĄBROWSKI, Ma.E.*



**DIRECTOR**  
Institute of Precision Mechanics

*prof. Aleksander NAKONIECZNY, D. Eng. Dr h.c*

Certificate can be published only by Certificate Owner without comments, abbreviations and changes.

Warsaw, November 30, 2019