

NOTIFIED BODY 1396 Osloboditeľov 282, 059 35 Batizovce, Slovakia Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0167

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Operable fabric curtain Flammatex Firecurtain, type Flammatex E120 / EW30

covered by EN 13241: 2003 + A2: 2016, used as industrial, commercial and/or garage fabric rolling shutter intended for the installation in areas in the reach of persons and for which the main intended use is giving safe access for goods and vehicles accompanied or driven by persons. The product mode of operation is normally held open but self-closing in case of fire. The conditions of product use are described in the Assessment and verification of constancy of performance No. C1396/19/0033/2401/SC issued by FIRES, s.r.o., Notified Body No. 1396, Slovak Republic on 10. 12. 2019. The product is

placed on the market under the name or trade mark of

BVS BRANNVERNSYSTEMER AS Nedre Banegate 19, 4014 Stavanger, Norway

and produced in the manufacturing plant(s)

BVS Fire Protection Ltd. Kotyházi út 1, 3104 Salgótarján, Hungary.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 16034: 2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 10. 12. 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce 10. 12. 2019



Ing. Henrieta Lapková Head of Product Certification Body

117114

FIRES 136a/C-31/01/2017-E